

AB Tip İnceleme Sertifikası EU Type-Examination Certificate

Belge No / Certificate No : 244-21-01-R02

Belgelendirme Tarihi - Bir Sonraki Belge Tarihi /

Certification Date / Certificate Validity Date : 22.06.2021-19.05.2026

Belge Geçerlilik Tarihi / Document Validity Period: 5 yıl / 5 years

Firma Unvanı ve Adresi /

Company Name and Address

: IPOS MEDÍKAL DIŞ TİCARET A.Ş.

Eyüp Sultan Mah. Yadigar Sok. No: 14 Sancaktepe/

ISTANBUL

Ürün Adı /Modeller / Product Name / Models

Direktifi / Directive

Modülü/Kategori / Module / Category

: IPOS P-20

: 2016/425 REGULATION

: MNA M-2021-00831

: B MODÜLÜ/ KATEGORİ III

MODULE B / CATEGORY III

Test Rapor No/ları / Test Report No

Ürün Tipi / Product Type:

EN 149:2001+ A1:2009 Solunumla ilgili koruyucu cihazlar - Parçacıklara karşı koruma amaçlı filtreli yarım maskeler/ Respiratory protective devices - Filtering half masks to protect against particles

Ürünün Malzeme Bilgisi / Product Material Information: IPOS P-20 model ürünleri kumaş, elastik kayış, burun klipsi ve filtre katmanı kullanılarak imal edilmiştir./ IPOS P-20 model products are manufactured using fabric, elastic strap, nose clip, filter layer.

Revizyon nedeni / Reason for revision: Teknik değerlendirme raporu revize edilmiştir./ Technical evaluation report has been revised.

Volkan AKIN 22.06.2021 Karar Verici / Approver

Okan AKEL 22,06,2021 Şirket Müdürü / General manager







MNA Laboratuvarları San. Tic.Ltd .Şti
Adres: Küçükbakkalköy Mahallesi Yenidoğan Cad.No:21 Ataşehir/ İstanbul
Tel: 0216 574 07 08 Faks: 0216 575 13 31 www.mnalab.com




ATTACHMENTS (244-21-01-R02)

To certify the PPE product at Category III level, C2 or D module is accompanied by applying one of the conformity assessment methods along with the EU Type Examination (Module B).

Model: IPOS P-20

PPE SPECIFICATION	PERFORMANCE LEVELS
Classification	FFP2
Reusable / Single Shift Use	NR

PPE produced as a single unit to fit an individual user, all the necessary instructions for manufacturing such PPE on the basis of the approved basic model:




MNA LABORATORIES SAN. TIC. LTD. \$TI declares that the above-mentioned product meets the requirements of the directive according to the EU Directive 2016/425, the safety of the product is covered by the conditions and use specified in this certificate and in the technical file.

MNA Laboratuvarları San. Tic.Ltd .Şti
Adres: Küçükbakkalköy Mahallesi Yenidoğan Cad.No:21 Ataşehir/ İstanbul
Tel: 0216 574 07 08 Faks: 0216 575 13 31 www.mnalab.com



ATTACHMENTS (244-21-01-R02)



DOCUMENTS IN THE TECHNICAL FILE

- Basic Health Safety Requirements
- Risk Assessment
- Test Reports
- Technical Report (244-21-01-R02)



TECHNICAL EVALUATION REPORT (244-21-01-R02)

Report No

: 244-21-01-R02

Report Date

: 22.06.2021

Application No

: 244-21-01-R02

1. COMPANY INFORMATION:

IPOS MEDIKAL DIŞ TİCARET A.Ş.

Eyüp Sultan Mah. Yadigar Sok. No: 14 Sancaktepe/ ISTANBUL

E-mail: info@iposmedikal.com.tr

2. PPE INFORMATION:

Disposable and non-sterile half mask made of particulate protection fitler material.

3. PPE TYPE IDENTIFICATION

EN 149:2001+A1:2009 Respiratory protective devices – Filtering half masks to protect against particles - Requirements, testing, marking

4. PPE PICTURES





IPOS P-20 (Black, Gray, Pink, White, Blue)

5. PPE DIMENSIONS:

IPOS P-20 model has been found to be produced using standard and small sizes.

6. PPE PRODUCT MATERIAL INFORMATION:

The product is made of elastic strap, nonwoven fabric on the outer and inner layers and fitler material on the middle layer.

7. ESSENTIAL HEALTH AND SAFETY REQUIREMENTS

- A visual inspection was made according to EN 149:2001 +A1:2009 for ergonomics.
- Protection levels and degrees are defined by the manufacturer.
- Suitable construction materials were determined by visual inspection according to EN 149:2001 +A1:2009.

MNA LABORATUVARLARI SAN TÍG, LTD. ŞTİ.

MNA LABORATUVARLARI

TECHNICAL EVALUATION REPORT (244-21-01-R02)

8. ANALYSIS AND EVALUATIONS: EN 149:2001 +A1:2009

TESTS	PARAMETER	PARAMETER PERFORMANCE LEVELS				PERFORMAL E LEVELS	NC EVALUATION
		FFP1	FFP2	FFP3			
Part 7.3 Visual inspection	Shall also the markin supplied by the manu	THE STATE OF THE S		rmation	Appropriate		PASS
Banned Azo Dyes	< 30 mg/kg				< 5 mg/kg (Bla Gray, Pink, Whi Blue)	0.000	PASS
Part 7.4 Packaging	for sale packaged in	mask shall be offered such a way that they st mechanical damage			Appropriate		PASS
Part 7.5 Material	When conditioned in 8.3.2 the particle filt collapse.				Appropriate	*	PASS
Part 7.6 Cleaning and disinfecting	particle filtering half	ter cleaning and disinfecting the re-usable rticle filtering half mask shall satisfy the netration requirement of the relevant					Not applicable
Part 7.7 Practical performance	No negative commen the test subject regard evaluated.			And the second second	Appropriate		PASS
Part 7.8 Finish of parts	Parts of the device contact with the wear edge or burrs.				Appropriate		PASS
TESTS	PARAMETER	PERFO	ORMANO S	CE	RESULTS	PERFORMANC E LEVELS	EVALUATION
		FFP1	FFP2	FFP3			
Part 7.9.1 Total inward leakage	al inward the 50 individual b		See the table below	FFP2	PASS		
	At least 8 out of the <22 <8 <2 10 individual wearer arithmetic means				See the table below	FFP2	PASS

Total Inward Leakage (%)										
	Exercise 1	Exercise 2	Exercise 3	Exercise 4	Exercise 5	Average				
Subject 1 (As recieved)	8,2	7,2	6,4	8,4	6,7	7,4				
Subject 2 (As recieved)	7,9	5,5	6,0	6,7	6,6	6,5				
Subject 3 (As recieved)	7,6	8,8	6,1	8,4	8,8	7,9				
Subject 4 (As recieved)	7,5	8,2	8,0	8,5	6,8	7,8				
Subject 5 (As recieved)	7,3	8,5	7,9	5,6	7,4	7,3				
Subject 6 (After temperature conditioning)	8,8	9,5	9,0	9,7	8,9	9,2				
Subject 7 (After temperature conditioning)	7,6	7,8	7,5	6,5	7,4	7,4				
Subject 8 (After temperature conditioning)	7,7	8,8	7,3	7,4	7,6	7,8				



TECHNICAL EVALUATION REPORT (244-21-01-R02)

Subject 9 (After temperature conditioning)	6,3	8,8	8,8	8,4	9,0	8,3
Subject 10 (After temperature conditioning)	5,0	5,3	4,7	5,7	4,4	5,0

Subject facial dimensions

Subject	Face Length (mm)	Face Width (mm)	Face Depth (mm)	Mouth Width (mm)
1	133	132	132	65
2	125	144	116	67
3	126	135	124	75
4	123	133	134	74
5	117	135	122	73
6	122	142	133	66
7	113	132	114	75
8	135	123	123	65
9	122	135	133	74
10	135	142	125	83

TESTS PA	TESTS	PARAMETER	PERFORMANCE LEVELS		RESULTS PERFORMANCE LEVELS		EVALUATION
		FFP1	FFP2	FFP3			
Part 7.9.2 Penetration of filter	Sodium chloride, 95 L/min %, max	% 20	% 6	%1	See the table below	FFP2	PASS
material	Paraffin oil, 95 L/min %, max	% 20	%6	%1	See the table below	FFP2	PASS

Penetration of filter material	Sodium Chloride (%)	Paraffin Oil (%)	
As recieved	3,9	4,2	
As recieved	4,2	4,3	
As recieved	4,4	4,4	
After the simulated wearing treatment	4,2	4,6	
After the simulated wearing treatment	4,1	4,6	
After the simulated wearing treatment	4,7	4,8	
Mechanical strength and temperature conditioning	5,1	5,2	
Mechanical strength and temperature conditioning	5,0	5,3	
Mechanical strength and temperature conditioning	5,1	5,3	

TESTS	PARAMETER PERFORMANCE LEVELS		RESULTS	PERFORMANCE	EVALUATION			
		FFP1	FFP2	FFP3		LEVELS		
Part 7.10 Compatibility with skin	Materials shall not cause irritation or all health				Appropriate		PASS	
Part 7.11 Flammibility	Mask shall not burn for more than 5 s	or not to	continu	e to burn	Flame not seen	-	PASS	
Part 7.12 Carbondioxide content of the inhalation air	Shall not exceed an a	average o	f % 1		0,88 0,84 0,83		PASS	
Part 7.13	It can be donned and	d remove	deasily		Appropriate	•	PASS	



TECHNICAL EVALUATION REPORT (244-21-01-R02)

Head harness			
Part 7.14 Field of vision	The field of vision shall acceptable in practical performance test.	Appropriate	PASS
Part 7.15 Exhalation valve(s)	It shall withstand axially a tensile force of 10 N apply for 10 s. If fitted, shall continue to operate correctly after a continuous exhalation flow of 300 L/min over a period of 30 s.	Not applicable	Not applicable

TESTS PARAMETER	PARAMETER	PERFORMANCE LEVELS			RESULTS	PERFORMANCE	EVALUATION
		FFP1	FFP2	FFP3	3 5 5 5 5 5 6 6 6 6 6 6 6 6 6 6 6 6 6 6	LEVELS	Section Sections
Breathing Resistance Inhalation 95L/m	Inhalation 30L/min	0,6 mbar	0,7 mbar	1,0 mbar	See the table below	FFP2	PASS
	Inhalation 95L/min	2,1 mbar	2,4 mbar	3,0 mbar	See the table below	FFP2	PASS
	Exhalation 160L/min	3,0 mbar	3,0 mbar	3,0 mbar	See the table below	FFP2	PASS

Breathing Resistance (mbar)	Inhalation 30L/min	Inhalation 95L/min
As recieved	0,6	2,2
As recieved	0,6	2,2
As recieved	0,5	2,3
After temperature conditioning	0,5	2,3
After temperature conditioning	0,6	2,3
After temperature conditioning	0,5	2,2
After the simulated wearing treatment	0,5	2,3
After the simulated wearing treatment	0,6	2,3
After the simulated wearing treatment	0,6	2,3

Breathing Resistance 160L/min (mbar)	Facing directly ahead	Facing vertically upwards	Facing vertically downwards	Lying on the left side	Lying on the right side
As recieved	2,8	2,8	2,8	2,9	2,8
As recieved	2,9	2,8	2,8	2,9	2,8
As recieved	2,9	2,8	2,8	2,9	2,8
After temperature conditioning	2,9	2,8	2,8	2,8	2,8
After temperature conditioning	2,8	2,8	2,8	2,8	2,8
After temperature conditioning	2,8	2,8	2,8	2,8	2,8
After the simulated wearing treatment	2,8	2,8	2,9	2,8	2,8
After the simulated wearing treatment	2,8	2,8	2,9	2,8	2,8
After the simulated wearing treatment	2,8	2,8	2,8	2,8	2,8



TECHNICAL EVALUATION REPORT (244-21-01-R02)

TESTS	PARAMETER	PERFORMANCE LEVELS			RESULTS	PERFORMANCE LEVELS	EVALUATION
		FFP1	FFP2	FFP3			
Part 7.17 Clogging	After clogging the inhalation resistances shall not exceed. (valved)	4 mbar	5 mbar	7 mbar	Not applicable	5	Not applicable
	The exhalation resistance shall not exceed 3 mbar at 160 L/ min continuous flow. (valved)				Not applicable	•	Not applicable
	After clogging the inhalation and exhalation resistances shall not exceed. (valveless)	3 mbar	4 mbar	5 mbar	Not applicable		Not applicable
Part 7.18 Demountable part	All demountable parts (if fitted) shall be readily connected and secured were possible by hand.				Not applicable	*	Not applicable

9. DECISION PROPOSAL

Analysis and examinations IPOS P-20 model coded personal protective equipment; Respiratory Protective Devices EN 149:2001 +A1:2009- Filtered Half Masks for Protection Against Particles - Properties, Experiments and Marking standards are evaluated. It is recommended to be certified at the performance levels specified as a result of technical evaluations.

10. ATTACHMENTS

- Basic Health Safety Requirements
- Risk Assessment
- User Instruction

Reason for revision : The typo has been revised.

CONTROLLER : VOLKAN AKIN

SING :

DATE : 22.06.2021